

# EU-Type Examination - Production Type Certificate

This is to certify that:

Saudi Factory For Fire Equipment Co.  
2nd Industrial City  
Wasel No.7275 Unit 1, Street 234  
Al Kharj Road, PO Box 4441  
Riyadh  
14334  
Kingdom of Saudi Arabia

Holds Certificate Number:

CE 68753

In respect of:

**Fire Extinguisher Assemblies (stored pressure) as described in technical file SF/LP/01 Rev. 4**

On the basis of our examination under the requirements of Council Directive 2014/68/EU Module B - Production Type of the Pressure Equipment Directive

For and on behalf of BSI, a Notified Body for the above Directive (Notified Body Number 0086):



Gary Fenton, Global Product Certification Director

First Issued: 31/07/2002

Latest Issue: 20/12/2016

Expiry Date: 30/07/2022

Page: 1 of 2

...making excellence a habit.™

# EU-Type Examination - Production Type Certificate

No. CE 68753

## Additional Information

### Limitations of Certificate Validity

Fire extinguisher assemblies within the limits:

PS = 18.5 bar g

TS = -30°C to +60°C

Products: Fire extinguisher assemblies in the following models:


Dry Powder - PD1, PD2, PD4, PD6, PD6 Max, PD9, PD12

Water - WH600J, WH600S, WH900J, WH900S

Foam - FX6, FX6 Max, FX9

Wet Chemical - SKF6

Halotron - PHT2, PHT4, PHT6



First Issued: 31/07/2002

Latest Issue: 20/12/2016

Expiry Date: 30/07/2022

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.