

# Swinging-type Fire Doors Certified for Canada

See General Information for Swinging-type Fire Doors Certified for Canada

**SAUDI FACTORY FOR FIRE EQUIPMENT CO**

R22331

2ND INDUSTRIAL AREA

AL-KHARJ RD

PO BOX 58469

RIYADH, 11515 SAUDI ARABIA

Swinging doors may be provided as follows:

Max Rating	Door Type	Steel Covered Mineral Core			
		Steel Stiffened	Composite	Honeycomb Hollow Metal	Honeycomb Sheet Metal
3 Hr	Single with Single Point Lock/Rim, Mortise Fire Exit Hardware 450°F Temperature Rise	X	—	—	—
1 Hr	Single with Single Point Lock / Rim, Mortise Fire Exit Hardware 450 F (218 C) Temp Rise DoorPair with Astragal Single Point Lock, Mortise Fire Exit Hardware, Flush Bolts / Vertical Rod Fire Exit Hardware 450 F temp Rise Door	X	—	—	—

Last Updated on 2007-01-19

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."

# Fire Door and Fire Window Frames Certified for Canada

[See General Information for Fire Door and Fire Window Frames Certified for Canada](#)

## **SAUDI FACTORY FOR FIRE EQUIPMENT CO**

R22310

2ND INDUSTRIAL AREA

AL-KHARJ RD

PO BOX 58469

RIYADH, 11515 SAUDI ARABIA

Door frames: Welded three sided single frames for use in 3/4, 1-1/2, 3 hr locations. Maximum size of frame: 1200 mm in width and 2261 mm in height.

Door frames: Welded three sided pair type frames for use in 3/4, 1-1/2, 3 hr locations. Maximum size of frame: 2313 mm in width and 2269 mm in height.

Last Updated on 2007-01-19

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."

## Cabinets Certified for Canada

[See General Information for Cabinets Certified for Canada](#)

**SAUDI FACTORY FOR FIRE EQUIPMENT CO**

R39545

2ND INDUSTRIAL AREA

AL-KHARJ RD

PO BOX 58469

RIYADH, 11515 SAUDI ARABIA

**Fire Extinguisher Cabinet**, Model SFRC series, for use in Penetration Firestop System No. [W-K-7003](#).

[Last Updated](#) on 2018-10-10

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."